



### **Lead Sample Collection Information**

**DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.**

**School District Name: Skamania School District**

**School Name: Skamania Elementary School**

**School Code: 3405**

**Address: 122 Butler Loop Road Skamania WA 98648**

**Number of Samples Collected: 17**

**Date Collected: 4/19/2018**

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	5968	First Draw	Blank	Blank	<1	4/27/2018	Blank
Sample 2	5969	First Draw	Tap	Kitchen	12	4/27/2018	Triple sink, only water
Sample 3	5970	First Draw	Water Cooler	By front door	<1	4/27/2018	
Sample 4	5971	First Draw	Tap	Health Room	TB		Irregular use
Sample 5	5972	First Draw	Bubbler	Closest to front door	2	4/27/2018	In between bathrooms
Sample 6	5973	First Draw	Tap	Library	26	4/27/2018	
Sample 7	5974	First Draw	Bubbler	Next to K-2 room	<1	4/27/2018	In K-2 Hall
Sample 8	5975	First Draw	Tap	K-2 Room	TB		
Sample 9	5976	First Draw	Tap	3-4 Room	TB		
Sample 10	5977	First Draw	Tap	5-6 Room	TB		
Sample 11	5978	First Draw	Bubbler	Next to 5-6 Room and Special Ed.	2	4/27/2018	
Sample 12	5979	First Draw	Tap	Special Ed. Room	TB		Small leak
Sample 13	5980	First Draw	Tap	7-8 Room	18	4/27/2018	Restroom/ used for filling bottles
Sample 14	5981	First Draw	Tap	7-8 Computer Room	9	4/27/2018	Restroom/ used for filling bottles
Sample 15	5982	First Draw	Tap	Math Tutor	2	4/27/2018	Restroom/ used for filling bottles
Sample 16	5983	First Draw	Tap	Art Room	<1	4/27/2018	Restroom/ used for filling bottles
Sample 17	5984	First Draw	Tap	Art Room	<1	4/27/2018	Classroom sink

TB = Turbidity, further analysis required